

|  |                        |
|--|------------------------|
| Model  | Enviroair ASH014FHP    |
| Type of heat source  | Air-to-water           |
| Low-temperature heat pump  | No                     |
| Equipped with supplementary heater   | No                     |
| Heat pump combination heater   | Yes                    |
| Climate condition  | Average                |
| Temperature application  | Low temperature (35°C) |
| Applied standards EN14511, EN14825 (Space Heating), EN16147 (DHW), EN12102 |                        |

| Item  | Symbol  | Value       | Unit      | Item  | Symbol               | Value      | Unit              |
|---|---|-------------|-----------|---|----------------------|------------|-------------------|
| <b>Rated Heat Output <sup>(1)</sup></b>   | <b>P<sub>rated</sub></b>  | <b>13.7</b> | <b>kW</b> | <b>Seasonal space heating energy efficiency</b>   | <b>η<sub>s</sub></b> | <b>186</b> | <b>%</b>          |
| Declared capacity for heating for part load at indoor temperature 20°C and outdoor temperature T <sub>j</sub> |   |             |           | Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature T <sub>j</sub> |                      |            |                   |
| T <sub>j</sub> = -7°C (A Condition)   | P <sub>dH</sub>   | 12.14       | kW        | T <sub>j</sub> = -7°C (A Condition)   | COP <sub>d</sub>     | 2.79       | -                 |
| T <sub>j</sub> = +2°C (B Condition)   | P <sub>dH</sub>   | 7.94        | kW        | T <sub>j</sub> = +2°C (B Condition)   | COP <sub>d</sub>     | 4.52       | -                 |
| T <sub>j</sub> = +7°C (C Condition)   | P <sub>dH</sub>   | 5.20        | kW        | T <sub>j</sub> = +7°C (C Condition)   | COP <sub>d</sub>     | 6.68       | -                 |
| T <sub>j</sub> = +12°C (D Condition)  | P <sub>dH</sub>   | 3.75        | kW        | T <sub>j</sub> = +12°C (D Condition)  | COP <sub>d</sub>     | 8.52       | -                 |
| T <sub>j</sub> = bivalent temperature   | P <sub>dH</sub>   | 12.14       | kW        | T <sub>j</sub> = bivalent temperature   | COP <sub>d</sub>     | 2.79       | -                 |
| T <sub>j</sub> = TOL (E Condition)  | P <sub>dH</sub>   | 11.47       | kW        | T <sub>j</sub> = TOL (E Condition)  | COP <sub>d</sub>     | 2.59       | -                 |
| T <sub>j</sub> = -15°C (if TOL < -20°C)   | P <sub>dH</sub>   | -           | kW        | T <sub>j</sub> = -15°C (if TOL < -20°C)   | COP <sub>d</sub>     | -          | -                 |
| Bivalent temperature  |   |             |           | Operation limit temperature   |                      |            |                   |
| T <sub>biv</sub> = -7 °C  |   |             |           | TOL = -10 °C  |                      |            |                   |
| Cycling interval capacity for heating   |   |             |           | Cycling interval efficiency   |                      |            |                   |
| P <sub>cych</sub> = - kW  |   |             |           | COP <sub>cyc</sub> = -  |                      |            |                   |
| Degradation co-efficient <sup>(2)</sup>   |   |             |           | Heating water operating limit   |                      |            |                   |
| C <sub>dH</sub> = 0.90  |   |             |           | WTOL = 65 °C  |                      |            |                   |
| <b>Power consumption in modes other than active mode</b>  |   |             |           | <b>Supplementary heater</b>   |                      |            |                   |
| Off mode  | P <sub>OFF</sub>  | 0.014       | kW        | Rated heat output   | P <sub>sup</sub>     | -          | kW                |
| Thermostat-off mode   | P <sub>TO</sub>   | 0.024       | kW        | Type of energy input  | Electric             |            |                   |
| Standby mode  | P <sub>SB</sub>   | 0.014       | kW        |   |                      |            |                   |
| Crankcase heater mode   | P <sub>CK</sub>   | 0.000       | kW        |   |                      |            |                   |
| <b>Other items</b>  |   |             |           |   |                      |            |                   |
| Capacity control  | Variable  |             |           | Rated air flow rate, outdoors   |                      | 4060       | m <sup>3</sup> /h |
| Sound power level, indoors/outdoors   | L <sub>WA</sub>   | 65          | dB        | Rated water flow rate, indoor heat exchanger  |                      | -          | m <sup>3</sup> /h |
| Annual energy consumption   | Q <sub>HE</sub>   | 6012        | kWh       | Rated brine or water flow rate, outdoor heat exchanger  |                      | -          | m <sup>3</sup> /h |
| <b>For heat pump combination heater</b>   |   |             |           |   |                      |            |                   |
| Declared load profile   | -   |             |           | Water heating energy efficiency   | η <sub>wh</sub>      | -          | %                 |
| Capacity of heat pump   | P <sub>rated</sub>  | -           | kW        | Reference hot water temperature   | Θ <sub>WH</sub>      | -          | °C                |
| Daily electricity consumption   | Q <sub>elec</sub>   | -           | kWh       | Vol. of DHW accounted for in test   |                      | -          | Litres            |
| Annual electricity consumption  | AEC   | -           | kWh       | Standby heat loss / day   |                      | -          | kWh               |
| Contact Details:  | Firebird Heating Solutions Ltd., Údarás Industrial Estate, Baile Mhic Íre, Co. Cork, P12 HK51 |             |           |   |                      |            |                   |

(1) For heat pumps space heaters and heat pump combination heaters, the rated heat output P<sub>rated</sub> is equal to the design load for heating P<sub>designh</sub>, and the rated heat output of a supplementary heater P<sub>sup</sub> is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(2) If C<sub>dH</sub> is not determined by measurement then the default degradation coefficient is C<sub>dH</sub> = 0.9.

|                                    |  |
|------------------------------------|--|
| Model                              | Enviroair ASH014FHP                                      |
| Type of heat source                | Air-to-water   |
| Low-temperature heat pump          | No   |
| Equipped with supplementary heater | No   |
| Heat pump combination heater       | Yes  |
| Climate condition                  | Average  |
| Temperature application            | Medium Temperature (55°C)                                |
| Applied standards                  | EN14511, EN14825 (Space Heating), EN16147 (DHW), EN12102 |

| Item  | Symbol  | Value       | Unit      | Item  | Symbol               | Value      | Unit              |
|---|---|-------------|-----------|---|----------------------|------------|-------------------|
| <b>Rated Heat Output <sup>(1)</sup></b>   | <b>P<sub>rated</sub></b>  | <b>12.1</b> | <b>kW</b> | <b>Seasonal space heating energy efficiency</b>   | <b>η<sub>s</sub></b> | <b>136</b> | <b>%</b>          |
| Declared capacity for heating for part load at indoor temperature 20°C and outdoor temperature T <sub>j</sub> |   |             |           | Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature T <sub>j</sub> |                      |            |                   |
| T <sub>j</sub> = -7°C (A Condition)   | P <sub>dh</sub>   | 10.68       | kW        | T <sub>j</sub> = -7°C (A Condition)   | COP <sub>d</sub>     | 2.01       | -                 |
| T <sub>j</sub> = +2°C (B Condition)   | P <sub>dh</sub>   | 6.86        | kW        | T <sub>j</sub> = +2°C (B Condition)   | COP <sub>d</sub>     | 3.43       | -                 |
| T <sub>j</sub> = +7°C (C Condition)   | P <sub>dh</sub>   | 4.63        | kW        | T <sub>j</sub> = +7°C (C Condition)   | COP <sub>d</sub>     | 4.66       | -                 |
| T <sub>j</sub> = +12°C (D Condition)  | P <sub>dh</sub>   | 3.31        | kW        | T <sub>j</sub> = +12°C (D Condition)  | COP <sub>d</sub>     | 6.13       | -                 |
| T <sub>j</sub> = bivalent temperature   | P <sub>dh</sub>   | 10.68       | kW        | T <sub>j</sub> = bivalent temperature   | COP <sub>d</sub>     | 2.01       | -                 |
| T <sub>j</sub> = TOL (E Condition)  | P <sub>dh</sub>   | 9.19        | kW        | T <sub>j</sub> = TOL (E Condition)  | COP <sub>d</sub>     | 1.76       | -                 |
| T <sub>j</sub> = -15°C (if TOL < -20°C)   | P <sub>dh</sub>   | -           | kW        | T <sub>j</sub> = -15°C (if TOL < -20°C)   | COP <sub>d</sub>     | -          | -                 |
| Bivalent temperature  |   |             |           | Operation limit temperature   |                      |            |                   |
| T <sub>biv</sub>  |   | -7          | °C        | TOL   |                      | -10        | °C                |
| Cycling interval capacity for heating   |   |             |           | Cycling interval efficiency   |                      |            |                   |
| P <sub>cych</sub>   |   | -           | kW        | COP <sub>cyc</sub>  |                      |            | -                 |
| Degradation co-efficient <sup>(2)</sup>   |   |             |           | Heating water operating limit   |                      |            |                   |
| C <sub>dh</sub>   |   | 0.90        | -         | WTOL  |                      | 65         | °C                |
| <b>Power consumption in modes other than active mode</b>  |   |             |           | <b>Supplementary heater</b>   |                      |            |                   |
| Off mode  | P <sub>OFF</sub>  | 0.014       | kW        | Rated heat output   | P <sub>sup</sub>     | -          | kW                |
| Thermostat-off mode   | P <sub>TO</sub>   | 0.024       | kW        | Type of energy input  | Electric             |            |                   |
| Standby mode  | P <sub>SB</sub>   | 0.014       | kW        |   |                      |            |                   |
| Crankcase heater mode   | P <sub>CK</sub>   | 0.000       | kW        |   |                      |            |                   |
| <b>Other items</b>  |   |             |           | Rated air flow rate, outdoors   |                      |            |                   |
| Capacity control  | Variable  |             |           |   |                      | 4060       | m <sup>3</sup> /h |
| Sound power level, indoors/outdoors   | L <sub>WA</sub>   | 65          | dB        | Rated water flow rate, indoor heat exchanger  |                      |            |                   |
| Annual energy consumption   | Q <sub>HE</sub>   | 7202        | kWh       | Rated brine or water flow rate, outdoor heat exchanger  |                      |            |                   |
|   |   |             |           |   |                      | -          | m <sup>3</sup> /h |
| <b>For heat pump combination heater</b>   |   |             |           |   |                      |            |                   |
| Declared load profile   | XL  |             |           | Water heating energy efficiency   | η <sub>wh</sub>      | 130        | %                 |
| Capacity of heat pump   | P <sub>rated</sub>  | -           | kW        | Reference hot water temperature   | Θ <sub>WH</sub>      | 47.15      | °C                |
| Daily electricity consumption   | Q <sub>elec</sub>   | 6.026       | kWh       | Vol. of DHW accounted for in test   |                      | 288        | Litres            |
| Annual electricity consumption  | AEC   | 1288        | kWh       | Standby heat loss / day   |                      | 1.76       | kWh               |
| Contact Details:  | Firebird Heating Solutions Ltd., Údarás Industrial Estate, Baile Mhic Íre, Co. Cork, P12 HK51 |             |           |   |                      |            |                   |

(1) For heat pumps space heaters and heat pump combination heaters, the rated heat output P<sub>rated</sub> is equal to the design load for heating P<sub>designh</sub>, and the rated heat output of a supplementary heater P<sub>sup</sub> is equal to the supplementary capacity for heating sup(T<sub>j</sub>).

(2) If C<sub>dh</sub> is not determined by measurement then the default degradation coefficient is C<sub>dh</sub> = 0.9

